

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"



DELHI JAL BOARD; (GOVT. OF N.C.T. DELHI)
 QUALITY CONTROL LABORATORY,
 TRANS YAMUNA REGION TAHIRPUR DELHI-110093



NO: DJB/ACWA(TYR)/2021.....

DATE:- 04-02-2021

Analysis report of DJB Supply water samples collected from (1) Inlet Salwan Public School and (2) Outlet Salwan Public School, Kondli Gharoli, Complex, Mayur Vihar- III, Delhi-96.

Ref. No-Nil,

Challan No:- 271


dated:- 28-01-2021

S. No.	PARTICULARS	BIS:10500-2012 LIMITS		UNITS	RESULT	
		Desirable	Permissible		(INLET)	(OUTLET)
A.	Physical Examination					
1.	Date of collection	--	--	--	30/01/2021	30/01/2021
2.	Date of Analysis	--	--	--	31/01/2021	31/01/2021
3.	Colour	-	Clear	Clear
4.	Odour	-	Chlor.	Chlor.
5.	Turbidity	1.0	5.0	NTU	1.92	1.82
6.	P ^H Value	6.5-8.5	--	-	7.6	7.5
7.	Electrical Conductivity	--	--	µs/cm	177	178
8.	Total Dissolved Solids	500	2000	mg/l	115	116
B.	Chemical Examination					
9.	P ^h Alkalinity	45	NR	mg/l	NIL	NIL
10.	Total Alkalinity	200	600	mg/l	60	62
11.	Total Hardness	200	600	mg/l	74	76
12.	Calcium Hardness	mg/l	52	52
13.	Magnesium Hardness	mg/l	22	24
14.	Calcium as (Ca)	75	200	mg/l	20.8	20.8
15.	Magnesium as (Mg)	30	100	mg/l	5.28	5.76
16.	Ammonia	0.5	NR	mg/l	N.D.	N.D.
17.	Nitrite	mg/l	N.D.	N.D.
18.	Nitrate	45	NR	mg/l	0.65	0.81
19.	Sulphate	200	400	mg/l	22.0	28.6
20.	Chloride	250	1000	mg/l	8	8
21.	Fluoride	1.0	1.5	mg/l	0.49	0.26
22.	Total Iron	1.0	NR	mg/l	0.12	0.10
23.	Cyanide	0.05	NR	mg/l	N.D.	N.D.
24.	Residual Chlorine	0.2	1.0	mg/l	1.0	0.75
C.	Bacteriological Examination					
25.	Coliform count	Absent	No relaxation	MPN/100ml	0	0

This Report Pertains To The Particular Sample Only

REMARKS:- On the basis of above tested parameters, water samples conforms BIS: 10500-2012 and can be considered fit for drinking purpose.

[Signature]
 A/CHEMIST



[Signature]
 CHEMIST



[Signature]
 ACWA (TYR)

Reviewed
 9/02/21

[Signature]
 Principal
 Salwan Public School
 Kondli Gharouli Complex
 Mayur Vihar Phase-III,
 Delhi-110096

Asstt. Chief Water Analyst
 D.J.B. Govt. of N.C.T. of Delhi
 Quality Control Zonal Laboratory (Tyr)
 Tahir Pur Dilshad Garden, Delhi-93

East Delhi Municipal Corporation
Public Health Department
Shahdara (South) Zone
Karkardooma, Shahdara, Delhi-110032

No. DHO/Shah.(S)/2020/ 408

Dated:- 28-5-2020

School Health Certificate

1. Name of School : Salwan Public School
2. Location of the School : Kondli Gharoli Complex, Mayur Vihar,
Phase-III, Delhi-96
3. Timing of School : 8 A.M. to 2:30 P.M
4. No. of Rooms : 74
5. No. of Staff : 68 Teacher, 13 Ministerial Staff
6. No. of Students : 1669 (Boys-978, Girls-691)
7. No. of Desk & Chair : Provided
8. No. of Doors In each room : Exist in each room
9. No. of Windows in each room : Exist in each room
10. No. of Toilets : 28
11. No. of Urinals : 38
12. Building Structure : Pucca
13. Drinking Water : Provided
14. Electricity : Provided

At the time of inspection, school is found running under sanitary and hygiene conditions. This certificate is subject to provision of Fire Safety Certificate and its has no bearing on unauthorized construction of the premises if any and on any dispute regarding title of land.

This certificate/NOC is valid for (01) one year only.

The Principal,
Salwan Public School
Kondli Gharoli Complex,
Mayur Vihar, Phase-III, Delhi-96

Deena
Principal
Salwan Public School
Kondli Gharoli Complex
Mayur Vihar Phase-III,
Delhi-110096

[Signature]
28/5/2020
Deputy Health Officer
Shahdara (South) Zone
Deputy Health Officer
Shahdara (South) Zone
East Delhi Municipal Corporation